

This document must be retained for future reference.

It is the responsibility of the person installing the electrical equipment to ensure that the installation meets the requirements of the IET wiring regulations and is therefore 'fit for purpose'. Factors such as correct selection of components, cable sizing, protective devices and Earth bonding are all critical and should be checked prior to full testing and power-up. Any other regulations applicable to the equipment being installed such as the Machinery Directive and current health and safety legislation must also be adhered to.

All connections (including factory made) must be checked for the correct tightness prior to commissioning of the electrical installation.
All connections should also be inspected periodically to ensure correct tightness.

DO NOT USE POWER TOOLS ON THESE PRODUCTS



PB65C MNX Polycarbonate Contactor Enclosure for TC1 Contactors up to 65A



Dimensions

Material: Polycarbonate
Colour: RAL7035
Gasket: Polyurethane
Ingress Protection: IP66/67
Impact Resistance: IK10
UV Resistance: UL508
Non-toxicity: Halogen Free
Glow Wire Flammability
EN 60695-2-11: 960°C

