

This document must be retained for future reference.

It is the responsibility of the person installing the electrical equipment to ensure that the installation meets the requirements of the IET wiring regulations and is therefore 'fit for purpose'. Factors such as correct selection of components, cable sizing, protective devices and Earth bonding are all critical and should be checked prior to full testing and power-up. Any other regulations applicable to the equipment being installed such as the Machinery Directive and current health and safety legislation must also be adhered to.

All connections (including factory made) must be checked for the correct tightness prior to commissioning of the electrical installation. All connections should also be inspected periodically to ensure correct tightness.


DO NOT USE POWER TOOLS ON THESE PRODUCTS



5 Pole Enclosed Stud Terminals 50 - 240mm²

Features and benefits

- Colour-coded stud terminals for ease of installation.
- Used for generator hook-ups, cable extension or junction box.
- Choice of enclosures between powder-coated steel or GP



IP65 Epoxy Powder Coated (RAL 7035) Steel Enclosure (ME)

Part Number	Cable (mm ²)	Voltage (V)	Current (A)	Torque (Nm)	A	B	C	D	E	F	G	H	I	J
STC505PME	50	750	150	10	400	300	40	137	M8	150	59	254	354	8 DIA
STC955PME	95	1000	232		500	400	45	184		200	69	354	454	
STC1505PME	150		309	14	600	400	60	248	M12		80		554	
STC2405PME	240		415		800	600		276			90	554	754	

IP66 Glass Fibre Reinforced Polycarbonate Enclosure (GP)

Part Number	Cable (mm²)	Voltage (V)	Current (A)	Torque (Nm)	A	B	C	D	E	F	G	H	I	J
STC505PGP	50	750	150	10	400	300	40	137	M8	150	59	260	360	8 DIA
STC955PGP	95	1000	232		500	400	45	184		210	69	360	460	
STC1505PGP	150		309	14	600	400	60	248	M12		80		560	
STC2405PGP	240		415		800	600		276	300	90	560	760		

